



“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”

 Delhi Jal Board	<p>DELHI JAL BOARD ( GOVT. OF N.C.T. DELHI ) QUALITY CONTROL ZONAL LABORATORY (SOUTH) WATER WORKS OKHLA DELHI-110025</p> <p> Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015</p>	 एक कदम स्वच्छता की ओर
---	---	--

Dated:16.11.2022

No. DJB/DTQC/ CWA (W&S)III / ACWA (south)/ Paid/ Pact. /2022-2023/95-9:/09.11.2022

**Bacteriological Analysis Report as per IS 10500:2012**

<p>To New Horizon School Hazrat Nizamuddin , North of Humayun 's Thomb New Delhi -110013</p>	<p>Party Ref.No./Date: NHS/2022-23/83A/03.11.2022 Deptt.Challan No. /date: 232/04.11.2022 Dt.of sample collection: 09.11.2022 No. of Sample: Three(03) Collected by: Name - Sh. V.P Singh Desig.- Bacteriologist</p>
--	--

SL.No.	Particulars	Clarity	Residual chlorine	Total coliform/ E.coli in 100 ml sample
1.	Tap drinking Point After RO Nr. F- Block ,Gr.Floor, New Horizon School	Clear	NIL	1100
2.	Bore Well Near Mazhar E&F Block	Clear	NIL	0
3.	Bore Well Near A- Block & Play Ground	Clear	NIL	0

**RESULT:-** Collected water sample(s) as mentioned above at Sr.No. 2&3 were found bacteriological satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.

Collected water sample(s) as mentioned above at Sr.No.1 was found bacteriological unsatisfactory, hence it is advised that the water/source may not be fit for drinking/recreational purpose as such.

ACWA (SOUTH)

BACTERIOLOGIST(SOUTH)

FASSTT/BACT.

Assistant Chief Water Analyst  
Delhi Jal Board (A Govt. of Delhi)  
Zonal Laboratory (South)  
W.W. Okhla New Delhi - 110 025