

SOUTH DELHI MUNICIPAL CORPORATION
OFFICE OF THE DEPUTY HEALTH OFFICER, CENTRAL ZONE
JAL VIHAR, SHIV MANDIR MARG, NEW DELHI-24

No: DHO/CNZ/2021/D-319

Dated: 5. 7. 2021.

HEALTH CERTIFICATE

1. Name of the school: New Horizon School
2. Address of the school: North of Humayun's Tomb, Mathura Road, Nizamuddin, New Delhi - 110013
3. Shift : Morning Timing : 08:00 A.M to 02:00 P.M
4. No. of student: Boys : 725 Girls: 555 Total: 1280
5. No. of staff: Gents: 31 Ladies: 95 Total: 126
6. Accommodation provided are as under:-

- Floor areas in the classrooms are sufficient.
- Classrooms are well ventilated and well lighted.
- Classrooms are kept neat and clean.
- Building/Classrooms do not require white wash.
- Drinking water is wholesome .
- Latrine arrangement is sanitary.
- Number of Latrines and Urinals are sufficient.
- Separate toilet arrangement for Boys & Girls are present.
- Separate toilet arrangement for staff is present.
- The overall facilities are adequate.

Sheela
13-9-2021.

Principal
New Horizon School
North of Humayun's Tomb
Hzt. Nizamuddin, New Delhi-13
CBSE Aff. No. 2730159

18/9/21
Dy. Health Officer
Central Zone SDMC
Central Zone

Remark: This certificate is valid up to one year from date of issue and has no bearing on structural stability and unauthorized construction in the school premises.

DELHI JAL BOARD (Govt of NCT of Delhi)
ZONAL QUALITY CONTROL LABORATORY (SOUTH)
WATER WORKS, OKHLA, NEW DELHI-110025

No. DJB/DTQC/ CWA (C) / ACWA (south)/ Paid/ Bact. / 2021-2022/003/16.4.2021

Bacteriological Analysis Report as per IS 10500:2012

To M/s New Horizon School Party Ref.No./Date : NHS/2021-2022/83 A/
 Hazrat Nizamuddin Dt: 6.04.2021
 North of Humayun's Tomb Deptt. Challan No. /date: 14/7.04.2021
 Mathura Road Dt. of sample collection: 16.04.2021
 New Delhi - 110013 No. of Sample: Three (03)
 Collected by: Name- Sh. V. P Singh
 Desig.- Bact.

Sr.No. as in record book	Particulars	Clarity	Residual chlorine	Total coliform/ E.coli in 100 ml sample
1.	Tube well No. A-Block	clear	Nil	1100
2.	Tube well No. F-Block	clear	Nil	460
3.	Outlet Drinking water Tap	clear	Nil	150

RESULT: Collected water sample(s) as mentioned above at Sr.No. was/ were found bacteriological satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.

Collected water sample(s) as mentioned above at Sr.No. 1, 2, 3 was/ were found bacteriological unsatisfactory, hence it is advised that the water/source may not be fit for drinking/recreational purpose as such.

[Signature]
 26.4.2021
 Asstt. Bact.

[Signature]
 26/04/2021
 Bacteriologist (South)

[Signature]
 ACWA (South)

[Signature]
 13-9-2021

Principal
 New Horizon School
 North of Humayun's Tomb
 Hzt. Nizamuddin, New Delhi-13
 CBSE Aff. No. 2730159

Principal
 New Horizon School
 North of Humayun's Tomb
 Hzt. Nizamuddin, New Delhi-13
 CBSE Aff. No. 2730159

DELHI JAL BOARD

7857

GOVT. OF NCT OF DELHI


ZONAL LABORATORY (SOUTH) OKHLA WATER WORKS NEW DELHI -25


M/s New Horizon School, Hazrat Nizamuddin, North of Humayun's Tomb, Mathura Road New Delhi-110013, (1) T/W Nr A-Block, (2) T/W Nr F-Block, (3) outlet drinking water Tap Nr Park, at in School Campus.


Ref. : A.C.W.A. (SOUTH) Paid/2.0.21-22/P1-P3/Challan No-14, Dt. 07/04/2021 Date 30/04/2021

S.No.	PARTICULARS	Units	Result			Remarks	
			(1)	(2)	(3)		
PHYSICAL EXAMINATION							
1.	Date of Collection/Report		16-04-2021			Remarks: As per IS-10500-2012: On the basis of tested parameters, the above sample no. (1 & 2) is "Unfit" for drinking purpose and sample no. (3) results within the Permissible limit Subject to Beet. Satisfactory report.	
2.	Colour/Clarity	Hazen	Clear				
3.	Odour		No. Obj.				
4.	Turbidity (1-5)	NTU	1.26	0.57	1.14		
5.	Ph-Value (6.5-8.5)	-	7.0	6.8	7.5		
6.	Conductivity	µmho/cm ²	2470	2690	445		
7.	T.D.S. (500-2000)	mg/l	1606	1749	289		
CHEMICAL EXAMINATION							
1.	Phenolphthalin Alkalinity	mg/l	NIL	NIL	NIL		
2.	Total Alkalinity as CaCO ₃ (200-600)	mg/l	436	420	58		
3.	Total Hardness as CaCO ₃ (200-600)	mg/l	540	900	84		
4.	Carbonate Hardness	mg/l	436	420	58		
5.	Non Carbonate Hardness	mg/l	104	480	26		
6.	Calcium Hardness	mg/l	360	568	52		
7.	Magnesium Hardness	mg/l	180	332	32		
8.	Ammonia (Free & Saline as N) (0.5)	mg/l	ND	ND	ND		
9.	Nitrite (as N)	mg/l	ND	ND	ND		
10.	Nitrate (as NO ₃) (45)	mg/l	131.0	151.0	27.0		
11.	Sulphate (as SO ₄) (200-400)	mg/l	292	268.2	36.0		
12.	Chloride (as Cl) (250-1000)	mg/l	252	328	48		
13.	Iron (as Fe) (0.3)	mg/l	0.12	0.10	0.06		
14.	Fluoride (as F) (1-1.5)	mg/l	0.58	0.58	0.14		
15.	Calcium as Ca (75-200)	mg/l	144.0	227.2	20.8		
16.	Magnesium as mg (30-100)	mg/l	43.2	79.68	7.68		
17.	Chromium (as Cr ⁶⁺) (0.05)	mg/l	-	-	-		
18.	Cyanide (as CN) (0.05)	mg/l	-	-	-		
19.	Copper (as Cu) (0.05-1.5)	mg/l	-	-	-		
20.	Residual Chlorine	mg/l	NIL	NIL	NIL		

Sheela
13-9-2021


ASSTT. CHEMIST


Principal
New Horizon School
North of Humayun's Tomb
Hzt. Nizamuddin, New Delhi-13
CBSE Aff. No. 2730159


ACWA

Copy to : 1. Director T&QC
2. CWA (W&S) III